Eurofins Product Testing A/S
Smedeskovvej 38
DK-8464 Galten
Denmark

Tel. +45 70 22 42 76
Fax +45 70 22 42 75
CustomerSupport@eurofins.dk
www eurofins com/voc-testing

Torggler Srl
Via Prati Nuovi 9
39020 – Marlengo (BZ)
ITALY

Date
1 December 2020

Our ref.
392-2016-00179802_04_rev1

Test Report – LEED 2009 EQ c4.1, SCAQMD rule 1168 (2005)

Sample material

Sample identification	**CA POLY - EKOR – Batch No. 1614899 (05-2016)**
Product type	Multipurpose Construction Adhesive
Product data, according to manufacturer	Density: 1.7 g/ml at 20 °C ** Water content: 0 g/l** Exempt compounds: none ***
Date received	09-05-2016
Analytical period	09-05-2016 – 03-06-2016

Methods applied

Method	Principle	Parameter	Detection limit	Uncertainty, U_m (%)
LEED 2009 EQ c4.1 ASTM D 2369 - 10	Gravimetric	Total Volatiles, SCAQMD rule 304	1 g/l	10 %
Volatile content of the sample was determined gravimetrically by heating up to 110 °C during 60 minutes. The result is the average of double testing. The result was calculated as: ([g all volatiles] - [g water] - [g exempt compounds]) / ([l material] - [l water] - [l exempt compounds])				

U_m (%): The expanded uncertainty U_m is equal to 2 x RSD%, see also www eurofins dk/uncertainty.

Analytical results

	Solid content, % mass	Water content, % mass	Exempt compounds, % mass	VOC less water less exempt compounds, g/l	VOC limit g/l
CA POLY - EKOR	97.8	0**	0***	37	70*

* VOC limit for “Multipurpose Construction Adhesive”
** Given by the client
*** No information about exempt compounds. Set to zero.

Eurofins Product Testing A/S

Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry

Morten Sielemann
Analytical Chemist

The test results relate only to the items tested.
The report shall not be reproduced except in full without the written approval of the testing laboratory.

Version History

Report date	Report number	Modification
01/12/2020	392-2016-00179802_04_rev1	The company has legally changed its name from “Torggler Chimica S.p.A.” to “Torggler Srl”. This version is considered valid.
10/01/2020	392-2016-00179802_04	This version is no longer valid.

The test results relate only to the items tested.
The report shall not be reproduced except in full without the written approval of the testing laboratory.